

NordREG Cross Border seminar

Johan Roupe, Swedish Energy Markets Inspectorate

November 19th 2021

Ei has taken an information order

Svenska kraftnät is required:

- **to report %RAM and %internal flow values for each of the three limiting CNECs per market time unit (MTU). This reporting shall continue until the flow-based CCM is implemented.**
- **to provide data on how countertrade and redispatch is used within Sweden and outside of Sweden to alleviate the situation. This is also to be reported per market time unit.**
- **to submit a thorough description of all planned infrastructure measures that will alleviate the transmission restrictions. This shall be reported within 6 months from the date of the decision.**

Svenska kraftnät's derogation request

- Ei is currently handling the request and has asked Svenska kraftnät for more information.
- EV, DUR and NVE have formally opposed the derogation.